



rfo-sfps-vadodara@gujarat.gov.in



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/RFOVAD/2023/00035025
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/RFOVAD/2023/00035025/R1

Date: 06/10/2024

Building Occupancy/Category: Educational (non-residential)

To,

RIKESH YADAV
NEAR ANAND CHOKDI DHARMAJ RAOD BORSAD BORSAD BORSAD Anand 388540
Fire Region: Vadodara RFO
Mobile No: 7043070403 Email ID: info@safetyalliance.in

This has reference to your Application No. 2024/00065755 dated 12/06/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise VATSALYA INTERNATIONAL SCHOOL (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: BORSAD
5. Name of Block(s): 01

The building/premise was inspected on 06/10/2024 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 06/10/2024
2. Six monthly inspection was done on 06/10/2024

The Fire Safety Certificate is renewed for a period of two (2) years upto 06/10/2026 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



Digitally Verified

Digitally verified by: Shaileshkumar Haribhai Patel
Fire Safety Officer - Advance (FSO-A)
2021/000420

Date: 06/10/2024
Time: 08:45 PM



FSCA/O/RFOVAD/2023/00035025/R1

PRINCIPAL
VATSALYA INTERNATIONAL SCHOOL
BORSAD

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.